

## PERMIT APPLICATION

# NY State Unified Solar Permit

Unified solar permitting is available statewide for eligible solar photovoltaic (PV) installations. Municipal authorities that adopt the unified permit streamline their process while providing consistent and thorough review of solar PV permitting applications and installations. Upon approval of this application and supporting documentation, the authority having jurisdiction (AHJ) will issue a building and/or electrical permit for the solar PV installation described herein.

### PROJECT ELIGIBILITY FOR UNIFIED PERMITTING PROCESS

By submitting this application, the applicant attests that the proposed project meets the established eligibility criteria for the unified permitting process (subject to verification by the AHJ). The proposed solar PV system installation:

- Yes  No 1. Has a rated DC capacity of 25 kW or less.
- Yes  No 2. Is not subject to review by an Architectural or Historical Review Board. (If review has already been issued answer YES and attach a copy)
- Yes  No 3. Does not need a zoning variance or special use permit. (If variance or permit has already been issued answer YES and attach a copy)
- Yes  No 4. Is mounted on a permitted roof structure, on a legal accessory structure, or ground mounted on the applicant's property. If on a legal accessory structure, a diagram showing existing electrical connection to structure is attached.
- Yes  No 5. The Solar Installation Contractor complies with all licensing and other requirements of the jurisdiction and the State.
- Yes  No 6. If the structure is a sloped roof, solar panels are mounted parallel to the roof surface.

For solar PV systems not meeting these eligibility criteria, the applicant is not eligible for the Unified Solar Permit and must submit conventional permit applications. Permit applications may be downloaded here: [Town of Brunswick Building Department Website](#) or obtained in person at 336 Town Office Road during business hours of 8am-4pm.

### SUBMITTAL INSTRUCTIONS

For projects meeting the eligibility criteria, this application and the following attachments will constitute the Unified Solar Permitting package.

- This application form, with all fields completed and bearing relevant signatures.
- Permitting fee based on the cost of construction, payable by cash or check made payable to the Town of Brunswick will be required prior to permit issuance
- Required Construction Documents for the solar PV system type being installed, including required attachments.

Completed permit applications can be submitted electronically to [cgolden@TownofBrunswick.org](mailto:cgolden@TownofBrunswick.org) or in person at 336 Town Office Rd during business hours 8am-4pm.

### APPLICATION REVIEW TIMELINE

Permit determinations will be issued within 90 calendar days upon receipt of complete and accurate applications. The municipality will provide feedback within 30 calendar days of receiving incomplete or inaccurate applications.

### FOR FURTHER INFORMATION

Questions about this permitting process may be directed to Charles Golden (518)279-3461 x111

## PROPERTY OWNER

Property Owner's First Name

Last Name

Title

Property Address

City

State

Zip

Section

Block

Lot Number

## EXISTING USE

Single Family

2-4 Family

Commercial

Other

## PROVIDE THE TOTAL SYSTEM CAPACITY RATING (SUM OF ALL PANELS)

Solar PV System: \_\_\_\_\_ kW DC

## SELECT SYSTEM CONFIGURATION

Make sure your selection matches the Construction Documents included with this application.

Supply side connection with microinverters

Load side connection with DC optimizers

Supply side connection with DC optimizers

Load side connection with microinverters

Supply side connection with string inverter

Load side connection with string inverter

## SOLAR INSTALLATION CONTRACTOR

Contractor Business Name

Contractor Business Address

City

State

Zip

Contractor Contact Name

Phone Number

Contractor License Number(s)

Contractor Email

Electrician Business Name

Electrician Business Address

City

State

Zip

Electrician Contact Name

Phone Number

Electrician License Number(s)

Electrician Email

Please sign below to affirm that all answers are correct and that you have met all the conditions and requirements to submit a unified solar permit.

Property Owner's Signature

Date

Solar Installation Company Representative Signature

Date

## SUBMITTAL REQUIREMENTS SOLAR PV 25KW OR LESS (ATTACHMENTS)

# NY State Unified Solar Permit

This information bulletin is published to guide applicants through the unified solar PV permitting process for solar photovoltaic (PV) projects 25 kW in size or smaller. This bulletin provides information about submittal requirements for plan review, required fees, and inspections.

### PERMITS AND APPROVALS REQUIRED

The following permits are required to install a solar PV system with a nameplate DC power output of 25 kW or less:

- a) Unified Solar Permit
- b) Town of Brunswick Building Permit Planning review is not required for roof mount solar PV installations of this size.

Fire Department approval is not required for solar PV installations of this size.

### SUBMITTAL REQUIREMENTS

In order to submit a complete permit application for a new solar PV system, the applicant must include:

- a) Completed Standard Permit Application form which includes confirmed eligibility for the Unified Solar Permitting process. This permit application form can be downloaded at Town of Brunswick web site under the Building Department Tab
- b) Construction Documents, with listed attachments. Construction Documents must be by stamped and signed by a New York State Registered Architect or New York State Licensed Professional Engineer.

The Town of Brunswick, through adopting the Unified Solar Permitting process, requires contractors to provide construction documents, such as the examples included in the Understanding Solar PV Permitting and Inspecting in New York State document. Should the applicant wish to submit Construction Documents in another format, ensure that the submittal includes the following information:

- Manufacturer/model number/quantity of solar PV modules and inverter(s).
- String configuration for solar PV array, clearly indicating the number of modules in series and strings in parallel (if applicable).
- Combiner boxes: Manufacturer, model number, NEMA rating.
- From array to the point of interconnection with existing (or new) electrical distribution equipment: identification of all raceways (conduit, boxes, fittings, etc.), conductors and cable assemblies, including size and type of raceways, conductors, and cable assemblies.
- Sizing and location of the EGC (equipment grounding conductor).
- Sizing and location of GEC (grounding electrode conductor, if applicable).
- Disconnecting means of both AC and DC including indication of voltage, ampere, and NEMA rating.
- Interconnection type/location (supply side or load side connection)
- For supply side connections only, indication that breaker or disconnect meets or exceeds available utility fault current rating kAIC (amps interrupting capacity in thousands).
- Ratings of service entrance conductors (size insulation type AL or CU), proposed service disconnect, and overcurrent protection device for new supply side connected solar PV system (reference NEC 230.82, 230.70).
- Rapid shutdown device location/method and relevant labeling.

c) (For Roof Mounted Systems) A roof plan showing roof layout, solar PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, code exemptions, solar PV system fire classification, and the locations of all required labels and markings.

d) Provide construction drawings with the following information:

- The type of roof covering and the number of roof coverings installed.
- Type of roof framing, size of members, and spacing.
- Weight of panels, support locations, and method of attachment.
- Framing plan and details for any work necessary to strengthen the existing roof structure.
- Site-specific structural calculations.

e) Where an approved racking system is used, provide documentation showing manufacturer of the racking system, maximum allowable weight the system can support, attachment method to roof or ground, and product evaluation information or structural design for the rack.

## PLAN REVIEW

Permit applications can be submitted to the Town of Brunswick Building Department in person at 336 Town Office Rd and electronically through Fax at (518) 279-4352

## FEES

For structural alterations, additions, enlargements or conversions to or in existing structures, such as the completion of expansion attics so as to make additional rooms or the addition of additional rooms to existing structures or adding, extending, or enclosing porches, when the cost of construction is two thousand dollars (\$2,000.) or less: one dollar fifty cents (\$1.50) per each one hundred dollars (\$100.) or such cost. For all structural alterations included within this sub-section, the cost of which is more than two thousand dollars (\$2,000.), the rates for such permits shall be the same as hereinafter provided in Subsection A (11) hereof.

- a. Where the total cost of construction of the work is five thousand dollars (\$5,000.) or less: one hundred dollars (\$100.00).
- b. For each additional one thousand dollars (\$1,000) or fraction thereof over five thousand dollars (\$5,000.) up to and including twenty-five thousand dollars (\$25,000.): (\$15.).
- c. For each additional one thousand dollars (\$1,000) or fraction thereof over twenty-five thousand dollars (\$25,000), up to and including fifty thousand dollars (\$50,000), (\$12).
- d. For each additional one thousand dollars (\$1,000) or fraction thereof over fifty thousand dollars (\$50,000), up to and including one hundred thousand dollars (\$100,000.) ten dollars (\$10).
- e. For each additional one thousand dollars (\$1,000) or fraction thereof exceeding one hundred thousand dollars (\$100,000): five dollars (\$5.).

## INSPECTIONS

Once all permits to construct the solar PV installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar PV system. On-site inspections can be scheduled by contacting Charles Golden by telephone at (518)279-3461 x111 or electronically at [cgolden@townofbrunswick.org](mailto:cgolden@townofbrunswick.org). Inspection requests require 24 hours advance notice. Electrical inspections are done by a third party. Authorized third party electrical inspectors are as follows: The Inspector LLC, Middle Department Inspection Agency, Commonwealth Electrical Inspection Service and New York Atlantic-Inland.

In order to receive final approval, the following inspections are required:

**Final Electrical Inspection:** The applicant must contact an approved electrical inspector when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application. The applicant must have ready, at the time of inspection, the following materials and make them available to the inspector:

- Copies of as-built drawings and equipment specifications, if different than the materials provided with the application.
- Photographs of key hard to access equipment, including;
  - Example of array attachment point and flashing/sealing methods used.

- Opened rooftop enclosures, combiners, and junction boxes.
- Bonding point with premises grounding electrode system.
- Supply side connection tap method/device.
- Module and microinverter/DC optimizer nameplates.
- Microinverter/DC optimizer attachment.

Final Code Inspection: The applicant must contact the Town of Brunswick Building Department when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application.

The Town of Brunswick has adopted a standardized inspection checklist, which can be found in the Understanding Solar PV Permitting and Inspecting in New York State document, found here: [NYSERDA](#)

The inspection checklist provides an overview of common points of inspection that the applicant should be prepared to show compliance. If not available, common checks include the following:

- Number of solar PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- Solar PV array is properly grounded.
- Electrical boxes and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductor's ratings and sizes match plans.
- Appropriate signs are property constructed, installed and displayed, including the following:
  - Sign identifying PV power source system attributes at DC disconnect.
  - Sign identifying AC point of connection.
  - Rapid shutdown device meets applicable requirements of NEC 690.12.
- Equipment ratings are consistent with application and installed signs on the installation, including the following:
  - Inverter has a rating as high as max voltage on PV power source sign.
  - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
  - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
  - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
  - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the buss bar rating.

## UNIFIED SOLAR PERMITTING RESOURCES

The jurisdiction has adopted the following documents from the New York Unified Solar Permit process:

- Standard Application can be found at the Town of Brunswick web site under the Building Department tab
- Understanding Solar PV Permitting and Inspecting in New York State document, which includes sample construction documents, inspection checklist, design review checklist, and labelling guide NYSERDA

## DEPARTMENTAL CONTACT INFORMATION

For additional information regarding this permit process, please consult our departmental website at Town of Brunswick or contact the Building Department at (518)279-3461.